

## ***PRIVATE WELLS***

Each permit application to construct a well shall include the following:

1. The property owner's name, address, parcel number and telephone number.
2. The well driller's name, address, telephone, and proof of valid state registration.
3. A plan with a specified scale, signed by a registered surveyor or engineer, showing the location of the proposed well in relation to existing or proposed above or below ground structures.
4. A description and location of visible prior and current land uses within two-hundred (200) feet of the proposed well location, which represent a potential source of contamination, including but not limited to the following:
  - [a] Existing and proposed structures
  - [b] Subsurface sewage disposal systems
  - [c] Subsurface fuel storage tanks
  - [d] Public ways
  - [e] Utility rights-of-way within 500-1000 feet of the well site
  - [f] Any other potential sources of pollution
5. Proof that the owner of any property abutting the applicant's property has been notified of the applicant's intention to install a well.
6. A permit fee of \$25.00.

The permit shall be on site at all times that work is taking place. Each permit shall expire one (1) year from the date of issuance unless revoked for cause.

The issuance of a Water Supply Certificate by the Board shall certify that the private well may be used as a drinking water supply. A Water Supply Certificate must be issued for the use of a private well prior to the issuance of an occupancy permit for an existing structure or prior to the issuance of a building permit for new construction which is to be served by the well.

The following shall be submitted to the Board of Health to obtain a Water Supply Certificate:

1. A well construction permit.
2. A copy of the Water Well Completion Report as required by the Division of Water Resources (CMR 313, section 3.00).
3. A copy of the Pumping Test Report required pursuant to Section VII of these regulations.
4. A copy of the Water Quality Report required pursuant to Section VIII of these regulations.

All private wells shall be located a minimum of twenty-five (25) feet from the normal driving surface of any public roadway or a minimum of fifteen (15) feet from the road right-of-way, whichever is greater.